



Fire Marshal's Office
San Mateo County Fire
CAL FIRE

320 Paul Scannell Drive, San Mateo, California 94402 (650) 573-3846

Date: July 29, 2009

Revised: 3.22.2017

Number: CFS-001

Title: Alternate Materials or Methods Request

Approved: Mark Mondragon

Scope: The provisions of this standard shall outline the procedure and policy of the San Mateo County Fire Department for Requests for Alternate Materials or Methods of Construction or Alternate Design. This option is allowed under the authority of Section 104.9 of the California Fire Code.

Submittal: Applicant must submit two copies of the request, plans and all accompanying substantiation material, to the Fire Marshal at 320 Paul Scannell Dr. San Mateo Ca 94402. It is highly recommended that the submittal be prepared by a Licensed Engineer, Architect or Fire Protection Engineer depending on the area of the request.

Project Information:

Project Address: 12400 Skyline Blvd, Woodside, CA 94062
Project APN #: 067-250-030 Permit #: PLN2022-00109
Owner Name: Omid Zahedi
Owner Phone:
Owner Address: 12400 Skyline Blvd, Woodside, CA 94062
Petitioner Name: Dale Leda
Petitioner Phone: (650) 482-6300
Petitioner Address: 255 Shoreline Drive, Suite 200, Redwood City, CA 94065
Occupancy Type: Construction Type: Type 5B Sprinklered (Y/N) Y
Total Floor Area: 9,980 sf Floor Area per Floor:
End Use: The project proposes to construct a new two-story residence, and includes an existing accessory structure to remain. The project site is accessed via a private road off of Skyline Blvd and a driveway connecting to Misty Ridge Rd.

Request for Alternate: (Separate form for each request) The private road onsite accessed from Skyline Blvd does not meet California Fire Code standards and will delay response time to the 12400 Skyline Blvd property.

Justification: (Findings of Equivalency) It is expected that the reduced fire access road widths and the nonstandard turnaround will impact response time. To mitigate this, a sprinkler system designed to NFPA 13 requirements is proposed in lieu of NFPA 13R.

Petitioners Signature: Position: Date: