

## Amy Ow

---

**From:** Camille Leung  
**Sent:** Thursday, January 30, 2020 3:51 PM  
**To:** Melody Eldridge  
**Cc:** Amy Ow; Jessica Henderson-McBean; Kristen Outten; Sherry Liu  
**Subject:** RE: Scanned image from MX-3110N

Hi Melody,

Looks like we have Sherry's comments. Any more comments from you? After I get all comments, I can send them along to Noel. Need to get a civil on board will take a little more time but probably wise in this instance.

-----Original Message-----

**From:** Melody Eldridge  
**Sent:** Thursday, January 30, 2020 3:36 PM  
**To:** Camille Leung <cleung@smcgov.org>  
**Cc:** Amy Ow <aow@smcgov.org>; Jessica Henderson-McBean <JHenderson-McBean@swca.com>; Kristen Outten <koutten@swca.com>; Sherry Liu <xliu@smcgov.org>  
**Subject:** RE: Scanned image from MX-3110N

At a glance we will also want to know length of pipe and approximate elevation change between strip drain and energy dissipator. Also, what are they using for the dissipator rock? 4-6"?

-----Original Message-----

**From:** Camille Leung <cleung@smcgov.org>  
**Sent:** Thursday, January 30, 2020 3:06 PM  
**To:** Melody Eldridge <meldridge@smcgov.org>  
**Cc:** Amy Ow <aow@smcgov.org>; Jessica Henderson-McBean <JHenderson-McBean@swca.com>; Kristen Outten <koutten@swca.com>; Sherry Liu <xliu@smcgov.org>  
**Subject:** FW: Scanned image from MX-3110N  
**Importance:** High

Hi Melody,

Please see attached plan. My comments are:

- This should be marked as Erosion Control and temporary
- Need lot lines as orientation of where this will be installed on the Lots
- Need size of energy dissipater area -- Copying Sherry just to make sure this is ok to do (probably need to avoid areas of fill)

What do you think?

-----Original Message-----

**From:** Noel Chamberlain [mailto:noel@nexgenbuilders.com]  
**Sent:** Thursday, January 30, 2020 1:53 PM  
**To:** Camille Leung <cleung@smcgov.org>  
**Cc:** Neil Trenerry <neil@cervelliere.com>; Jack Chamberlain <jtuttlec@aol.com>; Bob Pellegrine <Bob.P@nexgenbuilders.com>

Subject: FW: Scanned image from MX-3110N

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hi Camille,

Please see attached storm water dissipater by pass for run off coming from Lexington, New Brunswick and Cobble hill streets.

Thanks,  
Noel